

# Foxboro Evo™ Process Automation System


## Product Specifications

# Foxboro®

by Schneider Electric

## PSS 31S-10EDITORS

### Control Editors



The components of Foxboro Evo™ system are interconnected to support the system's mission within the plant. Control Editors allow the system to be configured to support the required communications and further to develop control schemes required to operate the plant correctly. When configured and downloaded into a controller, the control scheme is connected to live data and its operation can be observed graphically. This enables the engineers, operators, and maintainers to determine the status quickly and to clear interlocks and permissives during plant evolutions.

### OVERVIEW

The Control Editors are constructed using the Microsoft® desktop metaphor and include several menus, tool bars and views, such as the Template Toolbox and Network View as shown in Figure 1. The Strategy Editor Area provides a drawing canvas and associated tables and Winforms used for the graphical construction of control strategies.

The Control Editors enable the user to design:  
Foxboro Evo Control Strategies, System Configuration, and Application Objects.

Control strategies are assigned to compounds, which are in turn assigned to individual control stations.

- ▶ A control station is the hardware platform that executes the regulatory, sequential, logical and supervisory control strategies contained in a compound assigned to the station.

- ▶ A compound is the top most container and is assigned to a physical control station. The compound contains a set of user-designed strategies.
- ▶ A strategy template is a configured object representing a functional control entity, engineered to be reusable. The Strategy is a collection of Blocks and inner Strategies that are typically linked together. A Strategy may be instantiated as a control entity such as a Loop.
- ▶ A Block is the fundamental control element and represents a specific type of control function. Foxboro Evo systems support over a hundred different Control Blocks.

## FEATURES

The Control Editors enable:

- ▶ Graphical construction and deployment of Foxboro Evo control strategies
- ▶ Construction of re-usable control strategy component and composite designs
- ▶ User-defined renderings of re-usable control strategy components and composites
- ▶ Printed reports of control strategy drawings and supporting information
- ▶ Live updates/edits of real-time values superimposed on control strategy drawings
- ▶ Bulk generation of control strategies from stored templates and external project data
- ▶ Bulk migration of control strategies from installed I/A Series® and Foxboro Evo systems
- ▶ Ability to import and export control strategy designs

- ▶ Ability to create and deploy Archestra® IAS Platforms, Engines, Application Objects.
- ▶ Support for configuring FOUNDATION fieldbus and PROFIBUS-based intelligent devices and fieldbus networks
- ▶ Remote Desktop Services (for stations with Windows 7 and Windows Server 2008 R2 Standard).

## BENEFITS

The Control Editors offer substantial engineering productivity and quality gains to application designers and project engineers during:

- ▶ Initial project engineering through programmatic interfaces to third-party applications and external file systems supporting XML information exchange
- ▶ All project lifecycle stages, where the documentation is kept in sync with the configuration, as modifications are made
- ▶ Large scale expansions and modifications to the current designs
- ▶ Interoperability with other Foxboro® and third-party applications.

They also offer enhanced value to those users who want to use the Foxboro Evo system in more than one project. They provide the ability to migrate intellectual property from one installation to another with extensive tools to edit that intellectual property to fit the circumstances of the new project.

The Control Editors offer exceptional value to current users of I/A Series and Foxboro Evo systems wanting to upgrade their existing system to the latest technology by providing utilities to convert the intellectual property residing in their existing system to the paradigms of the new system. This can include graphical representations of control strategies.

This tool set is built upon and conforms to industry standards including Microsoft.NET Framework and ArchestrA Framework. Graphical editors within the configuration tool set utilize and take advantage of Microsoft Visio® application as the rendering engine.

The Control Editors provide graphical design, configuration, deployment and commissioning tools for systems using protocols such as PROBIFUS and FOUNDATION Fieldbus (FF).The graphical design tool for Strategy construction is shown in Figure 1.

The server for the Control Editors supports concurrent client access with record locking.




Figure 1. Control Editors Navigation

## STRATEGY CONSTRUCTION

A new strategy is developed by deriving a new template or instance from the base or derived strategy, naming it and opening it. This creates a new drawing canvas for constructing the strategy. Base or user-derived Block templates are dropped onto the drawing canvas and linked together by connecting

exposed parameters on the Blocks via a line drawing. Strategy connectors (inputs or outputs) are created and dropped onto the canvas and linked to block parameters. These connectors link Strategies together either from an inner to outer Strategy as discussed earlier or from a peer-to-peer Strategy connection as shown below.




Figure 2. Constructing a Strategy

## Execution Order of Strategy Components

The Control Editors enable the user to determine the order of execution automatically based upon the data flow through the strategy or manually by selecting the order of execution.

The order of execution of Blocks/Strategies within a containing Strategy is important to avoid introducing unwanted dead time into the strategy execution order.




Figure 3. Setting the Execution Order

## Live Data Updates on Strategy Diagrams

The Control Editors provide a graphical display that superimposes real time updated values at the connections between blocks in a deployed strategy. It also provides the capability to access deployed control strategies from the Strategy Editor.

Blocks/Strategies are selectable for editing purposes. The user can then upload values in the target controller to the database or download settable parameters in the database to the target controller without implementing a deploy procedure.




Figure 4. Live Data Updates on a Strategy

## Block Properties and Behavior Specification

Once a control Strategy has been designed, its behavior and properties have to be specified. This primarily consists of specifying its constituent parts, namely base and user-derived Blocks.

Blocks are available as either base or user-derived templates which are available for reuse in Strategy templates or instances. In all cases specifying the properties and behavior of these blocks is the same.

A new Derived Block Template represents a specialization of the original Block type. Typical examples include specializing a base Analog Input block template to represent an iron-constant and thermocouple input block type as shown below.




Figure 5. Derived Thermocouple

Other specializations include modifying the appearance or exposing certain features of various function blocks. One example would be to derive a base PIDA block into a specialized SAMA representation of a control entity as shown below:




Figure 6. SAMA Representation

## Strategies

The Strategy editor enables users to nest Strategies. This specialization process enables the user to create libraries of Strategy Templates that are composed of sets of connected blocks.

To illustrate this capability, consider the example below where a Reactor Temperature Control Strategy template that is constructed from inner Strategy templates called CasHOL and SplitRange. These inner Strategy templates are formed from Foxboro Evo block types.

Notice the yellow connectors in the two inner Strategies become connectable properties of the blocks in the outer Strategy.





Figure 7. Construction Process


## Programmable Block Editors

Foxboro Evo systems offer programmable block types including several choices of general purpose calculator style block types [MATH, LOGIC, CALC, CALCA]; a series of block types programmed in the High Level Batch Language [HLBL]; block types programmed in Sequential Function Charts [FoxSFC] and a block type that is programmed in a Ladder Logic Diagram that executes in I/O Modules.


The Control Editors provide a text editor for programming the High Level Batch Language and a graphical editor for programming Sequential Function Charts and Ladder Logic Diagrams as shown below.



High Level Batch Language Editor



Sequential Function Chart Editor



Ladder Logic Diagram Editor

Figure 8. Programmable Block Editors

## SYSTEM CONFIGURATION

The Control Editors enable the user to construct a Foxboro Evo system configuration, including control stations and Fieldbus Modules by instantiating these base types and renaming them according to user preferences. Then an engineer uses the Network View to assign these stations and modules to their designated Unit Areas.

The example below shows five user defined Unit Areas in addition to the Unassigned Hardware node. These are Centrifugation, Purification, Reaction, Solvent Recovery, and Tank Farm. It further shows two workstations and three Controllers assigned to the Reaction Area and two FBMs assigned to the RX0100 Controller.




Figure 9. Network View of System Configuration

## Intelligent Device Configuration

Control Editors in combination with the Foxboro Field Device Manager for FOUNDATION fieldbus is used to provide Fieldbus device management throughout the asset's lifecycle, including function block and device configuration, calibration, commissioning, startup, diagnostics and replacement.

The Foxboro Field Device Manager for PROFIBUS is used in the same way for PROFIBUS device management. Detailed information regarding FOUNDATION fieldbus integration is provided in *Field Device Manager for FOUNDATION fieldbus* (PSS 31S-10FDMFF), with additional Control in the Field functionality provided in *Control Software with FOUNDATION fieldbus* (PSS 31S-10FF). Detailed information regarding PROFIBUS integration is provided in *Field Device Manager for PROFIBUS-DP Devices* (PSS 31S-10FDMPB).

## Bulk Generation of a Project

The Control Editors offer extensive engineering productivity tools such as the ability to bulk generate a project database from user defined templates combined with project specific information stored in Microsoft Excel® or CSV format, SaveAll format, IACC Export format, SysDef Export format, or in a proprietary XML document.

The Control Editors can also migrate control strategies stored in existing Foxboro Evo system installations from the data stored in existing control stations. The bulk data is first imported into a data grid allowing the user to inspect it and make any necessary additions or modifications.




Figure 10. Bulk Generation of a Project

Bulk generation has the capability for applying Visual Basic® scripts to selected portions of the grid such as specific strategies or compounds to make bulk edits to the information. Once the user is satisfied with the structure and content, this grid is then used to generate the requisite control strategies and system configuration.

## CONTROL STRATEGY DEPLOYMENT

Once a Strategy is correctly assigned to a Compound and the Compound to a Controller, it can be deployed using commands selected from the object in the Deployment View, or one of the other Control Editors' Application Views.

There are three targets updated in the deployment:

- ▶ Compounds and blocks are downloaded to the Foxboro Evo system including the assigned Controller and the Compound Summary Access (CSA).
- ▶ Security access settings for compound and block attributes are loaded into ArchestrA Security.
- ▶ ArchestrA History is updated with the collection points configured in the Compounds and blocks.

When a Strategy or Compound is later modified using the Control Editors, it must be re-deployed to implement the changes in the runtime system. When a Strategy or Compound is re-deployed, only the affected targets are updated, and only the modified parameters are downloaded.

## PSS 31S-10EDITORS

Page 12

### CONCURRENT ACCESS TO THE DATABASE

The Control Editors support multiple clients concurrently accessing the database via Remote Desktop Services (for stations with Windows 7 and Windows Server 2008 R2). Networked clients execute their application independently from the server and only communicate when a client session is opened or closed. Remote Desktop Services use the resources of the server to perform their operations and remote clients to provide a user interface. These utilize different resources within the network architecture and can be used in combination to achieve optimal performance.

### USER DEFINED APPLICATION OBJECTS

The Control Editors enable the user to construct Application Objects and deploy them to the Foxboro Evo Control Software Application Environments hosted by AW70 platforms and ArchestrA Industrial Application Servers. These are created by the Galaxy Repository. The following example depicts an OLEDB database application created as an Application Object.




Figure 11. Application Object to Read/Write to a Database

## ACCESS SECURITY

The Control Editors utilize an ArchestrA Role-based security model where users subscribe to different roles depending upon their job requirements. Roles have associated access permissions and security groups. Security groups have various plant areas assigned to them.

A user's subscription to a particular role provides access to specific security groups (plant areas) with specified access permissions (Operate, Secured Write, and so forth) in those groups.

The authentication process is *user\_name* and *password*.

## CHANGE TRACKING WITH FOXCTS SOFTWARE

The Control Editors provide an integration with FoxCTS Change Tracking software. All control configuration and program changes deployed to control processors from the Control Editors are reported to FoxCTS software to provide tracking of

control system changes to help meet regulatory body requirements. Examples of program changes are HLBL or FoxSFC program changes in Sequence Blocks or Ladder Logic Diagram (LLD) program changes in PLB Blocks.

## RELATED PRODUCT SPECIFICATIONS

Further details regarding functionality provided within the Control Editors can be found in:

- ▶ *Logic Block Editor and Live Data Display*  
(PSS 31S-10LBEDIT)
- ▶ Scripting with Direct Access  
(PSS 31S-10SCRIPT)

## HARDWARE AND SOFTWARE REQUIREMENTS

### **Control Editors Server**

- ▶ Software Version: Supports Control Core Services software v9.0 or later
- ▶ Workstation/server type: H91, P91, H90, and P90
  - Intel Pentium® 4, 1.8 GHz (or higher) processor
- ▶ Operating System: Microsoft Windows® Server 2008 R2 Standard
- ▶ Database Software: Microsoft SQL Server® 2008<sup>(1)</sup>
- ▶ Memory: 4.0 gigabytes of main memory
- ▶ Hard Disk: Recommended: 16.0 GB free disk space
- ▶ Video Graphic Accelerator Card: 32 MB of memory
- ▶ Communications Network: 100 Mbps TCP/IP Switched Ethernet.

- ▶ Hard Disk: Recommended: 16.0 GB free disk space
- ▶ Video Graphic Accelerator Card: 32 MB of memory
- ▶ Communications Network: 100 Mbps TCP/IP Switched Ethernet.

### **Terminal Services or Remote Desktop Services Client**

- ▶ On Platform Station Type: H91, P91, H90, and P90
- ▶ Off-Platform Station Type: For Remote Desktop Services, Microsoft Windows Server 2008 R2 Standard.
- ▶ Memory: 4.0 gigabytes of main memory
- ▶ Database Software: Microsoft SQL Server 2008<sup>(1)</sup>
- ▶ Hard Disk: 32.0 GB free disk space.

### **Control Editors Client**

- ▶ Software Version: Supports Control Core Services software v9.0 or later
- ▶ Workstation/server type: H92 or P92
- ▶ Operating System: Microsoft Windows® 7, Microsoft Windows Server 2008 R2 Standard
- ▶ Computer: Intel Pentium 4, 1.8 GHz (or higher) processor
- ▶ Memory: 2.0 gigabytes of main memory

---

(1) Requires Microsoft.NET 2.0 to be installed. Microsoft .NET 1.1 is included as part of the Control Editors installation.



**Foxboro®**

by Schneider Electric

Invensys Systems, Inc  
10900 Equity Drive  
Houston, TX 77041  
United States of America  
<http://www.invensys.com>

Global Customer Support  
Inside U.S.: 1-866-746-6477  
Outside U.S.: 1-508-549-2424  
Website: <https://support.ips.invensys.com>

Copyright 2014 Invensys Systems, Inc.  
All rights reserved.  
Invensys is now part of Schneider Electric.

Invensys, Foxboro, and Foxboro Evo are trademarks owned by Invensys Limited, its subsidiaries and affiliates. All other trademarks are the property of their respective owners.